

Outdoor unit printed circuit board

Green		Red		Description of malfunction	Service diagnosis
LED-A		LED-A	LED-B		
				Normal	—
				Activation of protection device	Diagnosis ⑪
				Faulty thermistor	Diagnosis ⑫, ⑬, ⑭
		—	—	Faulty power supply system [Note 2]	Diagnosis ①
		—	—	Faulty power supply system, faulty outdoor unit printed circuit board [Notes 2, 3]	Diagnosis ④

Indoor unit printed circuit board

Green			Description of malfunction	Service diagnosis
Operation lamp	LED-A	LED-B		
			Normal	—
			Faulty indoor unit printed circuit board	—
			Faulty indoor unit printed circuit board if LED-A on outdoor unit printed circuit board is flashing	Diagnosis ①
—		—	Note 1	Diagnosis ②
—		—	Faulty power supply system, or note 1	Diagnosis ③
			Diagnose the failure using remote controller	—